


Tested element: **SGG Stadip 66.1**

Sample surface area S = 1.9 m<sup>2</sup>  
Volume of receiving room V = 86 m<sup>3</sup>  
Volume of source room 98 m<sup>3</sup>

FREQ. Hz	R dB
100	28,4
125	23,9
160	30,4
200	31,4
250	31,8
315	32,4
400	32,7
500	34,9
630	33,3
800	33,7
1000	35,8
1250	40,8
1600	43,5
2000	45,3
2500	47,1
3150	49,1
4000	51,4
5000	52,3



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

**R<sub>w</sub> (C; C<sub>tr</sub>) = 38 (-1 ; -3) dB**