


Tested element: **SGG Stadip 44.1**

Sample surface area S = 1,9 m²
Volume of receiving room V = 86 m³
Volume of source room 98 m³

FREQ. Hz	R dB
100	22,6
125	23,9
160	27,1
200	25,7
250	25,6
315	27,4
400	29,0
500	32,4
630	33,7
800	35,3
1000	35,9
1250	34,1
1600	31,4
2000	31,6
2500	36,0
3150	39,9
4000	44,4
5000	46,1



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

R_w (C; C_{tr}) = 34 (-1 ; -3) dB