


Tested element: **SGG Planilux 5 mm**

Sample surface area S = 1.9 m²
Volume of receiving room V = 86 m³
Volume of source room 98 m³

FREQ. Hz	R dB
100	20,6
125	21,1
160	25,1
200	23,7
250	24,2
315	25,3
400	25,4
500	29,4
630	31,0
800	32,5
1000	33,9
1250	34,8
1600	35,5
2000	32,3
2500	25,4
3150	28,4
4000	33,9
5000	35,4



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

R_w (C; C_{tr}) = 31 (-2 ; -2) dB