


**Tested element: SGG Stadip Silence 44.2**

Sample surface area            S =            1,9 m<sup>2</sup>  
 Volume of receiving room        V =            86 m<sup>3</sup>  
 Volume of source room                       98 m<sup>3</sup>

FREQ. Hz	R dB
100	23,5
125	27,0
160	30,8
200	28,0
250	30,5
315	30,6
400	31,3
500	34,1
630	35,6
800	36,6
1000	37,9
1250	39,0
1600	39,5
2000	39,4
2500	38,7
3150	40,9
4000	45,7
5000	48,3



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

**$R_w(C;C_{tr}) = 37 (0; -3) \text{ dB}$**