


Tested element: SGG CLIMATOP 8 (10 Ar) 4 (10 Ar) 4

 Specimen surface  
 Receiving room volume  
 Source room volume

 S = 1,88m<sup>2</sup>  
 V = 86m<sup>3</sup>  
 98m<sup>3</sup>

FREQ. Hz	R dB
100	23,5
125	20,8
160	18,9
200	20,6
250	25,0
315	25,8
400	28,7
500	32,4
630	36,9
800	39,3
1000	42,9
1250	43,2
1600	44,6
2000	46,4
2500	46,9
3150	43,1
4000	48,2
5000	52,5


 $R_w (C; C_{tr}) = 36 (-2 ; -6) \text{ dB}$ 

Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: