


Tested element: SGG CLIMATOP 4 (12 Ar) 4 (12 Ar) 4

 Specimen surface
 Receiving room volume
 Source room volume

 S = 1,88m²
 V = 86m³
 98m³

FREQ. Hz	R dB
100	23,8
125	19,5
160	16,6
200	15,3
250	18,6
315	21,0
400	23,8
500	27,7
630	32,5
800	36,9
1000	42,4
1250	46,2
1600	47,8
2000	48,2
2500	43,0
3150	33,4
4000	40,3
5000	45,5

 $R_w (C; C_{tr}) = 31 (-1 ; -5) \text{ dB}$


Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: