


Tested element: SGG CLIMATOP 44-1SI (14 Ar) 4 (14 Ar) 6

Specimen surface  
Receiving room volume  
Source room volume

S = 1,88m<sup>2</sup>  
V = 86m<sup>3</sup>  
98m<sup>3</sup>

FREQ. Hz	R dB
100	23,3
125	19,8
160	23,5
200	28,1
250	31,9
315	33,0
400	36,0
500	39,5
630	43,9
800	48,9
1000	52,3
1250	52,8
1600	52,8
2000	48,6
2500	48,5
3150	50,9
4000	57,3
5000	60,5

$R_w (C; C_{tr}) = 42 (-2 ; -7) \text{ dB}$



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: