


Tested element: **SGG CLIMATOP 6 (16 Ar) 3 (8 Ar) 4**

 Specimen surface  
 Receiving room volume  
 Source room volume

 S = 1,88m<sup>2</sup>  
 V = 86m<sup>3</sup>  
 98m<sup>3</sup>

FREQ. Hz	R dB
100	24,6
125	18,2
160	20,1
200	21,7
250	25,5
315	26,7
400	28,1
500	31,6
630	36,0
800	39,4
1000	44,0
1250	47,7
1600	46,2
2000	42,7
2500	41,7
3150	39,5
4000	43,4
5000	46,9

**R<sub>w</sub> (C;C<sub>tr</sub>) = 36 (-2 ; -5) dB**


Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: